

# TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104  
Phone No. (512) 322-2212 Fax No. (512) 463-6693

---

## PRODUCT EVALUATION

WIN-1081

Effective May 1, 2009

Revised July 1, 2011

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation **February 2012**.*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.*

**Series 311 Vinyl Horizontal Slider Windows, New and Replacement Construction, Non-impact Resistant,** manufactured by:

**Maritech Windows**

**1813 Kelly Blvd.**

**Carrollton, Texas 75006**

**Telephone: (469) 568-5636**

**[www.maritechwindows.com](http://www.maritechwindows.com)**

will be acceptable in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

## PRODUCT DESCRIPTION

The Series 311 window is a vinyl horizontal slider window. The vinyl horizontal slider window evaluated in this report is an individual, non-impact resistant window. This product evaluation report is for a vinyl horizontal slider window based on the following tested construction:

### General Description:

System	Description	Label Rating
1	Series 311 Vinyl Horizontal Slider Window; (OX)	LC-PG40 60 x 48 - HS
2	Series 311 Vinyl Horizontal Slider Window; (OX)	HS-R30 73 x 49

### Product Dimensions:

System	Overall Size	Sash Size	Fixed Daylight Opening Size
1	60" x 48"	30" x 46"	26 $\frac{13}{16}$ " x 45 $\frac{3}{8}$ "
2	73" x 49"	36 $\frac{7}{16}$ " x 47"	33 $\frac{1}{4}$ " x 46 $\frac{1}{4}$ "

---

**Glazing Description:**

System	Glass Construction <sup>1</sup>	Glazing Method <sup>2</sup>
1	IG-1	GM-1
2	IG-2	GM-1

Note: <sup>1</sup> See the "Glass Construction Key" for the glazing construction.

<sup>2</sup> See the "Glazing Method Key" for the glazing method description.

**Glass Construction Key:**

IG-1: The fixed sash and the operable sash contain sealed insulating glass units. The sealed insulating glass units are comprised of two double strength ( $\frac{1}{8}$ " ) annealed glass lites separated by a butyl spacer material with an aluminum substrate. The glass type and thickness used in the insulating glass unit of the tested assembly and in smaller assemblies shall comply with ASTM E 1300-04.

IG-2: The fixed sash and the operable sash contain sealed insulating glass units. The sealed insulating glass units are comprised of two single strength ( $\frac{3}{32}$ " ) annealed glass lites separated by a butyl spacer material with an aluminum substrate. The glass type and thickness used in the insulating glass unit of the tested assembly and in smaller assemblies shall comply with ASTM E 1300-04.

**Glazing Method Key:**

GM-1: The insulating glass units are set against structural silicone sealant. A vinyl (PVC) snap-in glazing bead secures the insulating glass units in place.

**Frame Construction:** The frame members are manufactured from extruded vinyl (PVC). The frame corners are mitered and welded construction. The fixed interlock stile is attached to the frame head and sill with screws.

**Sill Extender:** A rigid vinyl sill extender is secured to the interior leg of the frame sill with silicone sealant.

**Sash Construction:** The sash members are manufactured from extruded vinyl (PVC). The sash corners are mitered and welded construction.

**Reinforcement:**

**System 1:** Custom shaped extruded aluminum reinforcement is located in all of sash members and in the fixed meeting stile. The reinforcement extends the full length of the members.

**System 1:** Custom shaped extruded aluminum reinforcement is located in the lock stile and in the fixed meeting stile. The reinforcement extends the full length of the members.

**Hardware:**

- Metal sweep lock; Two (2) required; Located on the active sash stile, 9 inches from each end.
- Lock keepers; Two (2) required; Located on the fixed meeting stile.
- Plastic roller assembly (System 1); Two (2) required; Located on the bottom rail, one (1) at each end.
- Metal roller assembly (System 2); Two (2) required; Located on the bottom rail, one (1) at each end.

**Product Identification:**

**System 1:** A certification program label (NAMI) will be affixed to the window. The certification program label includes the manufacturer's code name (**MTW**); product name; **311 Horizontal Slider**; performance characteristics; the approved inspection agency (NAMI); and the applicable standard: AAMA/WDMA/CSA 101/I.S.2/A440-08.

**System 2:** A certification program label (NAMI) will be affixed to the window. The certification program label includes the manufacturer's code name (**MTW**); product name; **311 Horizontal Slider**; performance characteristics; the approved inspection agency (NAMI); and the applicable standard: AAMA/WDMA/CSA 101/I.S.2/A440-05.

## LIMITATIONS

**Design pressures:**

System	Maximum Width (in.)	Maximum Height (in.)	Design Pressures (psf)
1	60	48	± 40
2	73	49	± 30

**Impact Resistance:** These window assemblies do not satisfy the Texas Department of Insurance's criteria for protection from windborne debris. These window assemblies will need to be protected with an impact protective system when installed in areas where windborne debris protection is required.

**Acceptance of Smaller Assemblies:** Window assemblies with dimensions equal to or smaller than those specified above are acceptable within the limitations specified in this report.

## INSTALLATION INSTRUCTIONS

**General:** The window assembly shall be installed in accordance with the manufacturer's installation instructions. Detailed installation instructions and drawings are available from the manufacturer.

**Installation:**

**New Construction:** The wood wall framing members shall be minimum Spruce-Pine-Fir dimension lumber. The window shall be secured to the wall framing using the nailing fin of the window with either minimum No. 8 screws or minimum 2  $\frac{3}{8}$ " x 0.120" smooth shank nails. The fasteners shall be located approximately 2 inch from each corner and approximately 4 inches on center along the perimeter of the window. The fasteners shall be long enough to penetrate a minimum of 1  $\frac{1}{2}$  inches into the wall framing.

**Replacement Construction:** The wood wall framing members shall be minimum Spruce-Pine-Fir dimension lumber. The window shall be secured to the wall framing using the frame of the window with minimum No. 10 x 2  $\frac{1}{2}$ " screws. Along each side jamb, a minimum of four (4) fasteners are required. One fastener shall be located approximately 4 inches from each end and the remaining fasteners located in between, evenly spaced. Along the head, a minimum of four (4) fasteners are required. One fastener shall be located approximately 4 inches from each end and the remaining fasteners are located in between, evenly spaced. The fasteners shall be long enough to penetrate 1  $\frac{1}{2}$  inches into the wall framing.

**Note:** The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.